

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT ENGINEERING AND COMPLIANCE DIVISION PERMIT APPLICATION EVALUATION AND CALCULATIONS	PAGES 1	PAGE 1
	APPL NO 448748	DATE 7/5/2011
	PROCESSED BY AS08	CHECKED BY

TITLE V PERMIT (REV No. 01) EVALUATION

Applicant's Name Commerce Refuse to Energy Facility

Mailing Address P.O. Box 4998
Whittier, CA 90607-4998

Equipment Location 5926 Sheila Street
Commerce, CA 90040-2403

FACILITY ID 037336

APPLICATION 448748- Title V Minor Permit Revision

Background

Commerce Refuse to Energy Facility A/N 448748 was submitted for Title V permit revision (01). The Title V permit revision includes permit application 446552 which was submitted for a change of condition no. 13 to include an automatic controller at the outlet of the boiler for ammonia control.

Public notice is not required. For additional information please refer to the attached evaluation prepared for the EPA review. Note: Initial Title V (A/N 341039) was issued April 12, 2004.

Rules Evaluation

Reg. XXX:

A change of condition to condition no. 13 to include an automatic controller at the outlet of the boiler for ammonia control is considered a Title V Minor permit revision under Rule 3000(b)(12), since there is no emission increase and the modification of the equipment does not result in new or additional NSPS or NESHAP requirements and will be subject to an EPA review (Rule 3003 (j)). A public notice is not required.

Compliance is expected.

Conclusions and Recommendations

A Permit to Operate is recommended for application 446552. A revised Title V permit is recommended after the completion of EPA review.